

7272TG1 (High Voltage) Blower Motor F7 INVERTER			
CONSTANT	VALUE	CONSTANT	VALUE
A1-00	0	E1-04	Note 3
A1-01	2	E1-05	Note 4
A1-02	0	E1-06	Note 3
A1-03	Note 2	E1-07	3
B1-01	0	E1-08	26
B1-02	1	E1-09	1.5
B1-03	1	E1-10	13
C1-01	20	E2-01	Note 1
C2-01	1.0	L1-01	0
C6-01	0	L2-01	2
C6-02	0	L3-01	1
D1-01	Note 3	L3-02	100%
E1-01	Note 4	L3-03	100%
E1-03	F	L8-05	0
		L8-07	0

Note 1: Enter Ampere rating of inverter

Note 2: 2220 is initialize - otherwise 0

Note 3: Frequency of installation

Note 4: Voltage of installation

Release Date: June 2, 2009

Revision B